

Unitech



PT630D User Reference Guide

Version 1.1

NOTICE

This unit is equipped with a Li-ion battery pack. Battery power might be low due to storage. Recharge the battery when required. For procedures on how to charge the battery, please refer to *1.5 Quick Start*

NOTICE	2
Chapter 1: Introduction.....	4
1.1 Overview	4
1.2 Support.....	4
1.3 Customized PT630D	4
1.4 Technical Specification	5
1.5 Quick Start.....	6
1.6 Interface Ports	8
1.7 Using the Keyboard.....	8
1.8 Triggering Scanner Module.....	9
1.9 Application Development Environment.....	9
Chapter 2 Power System.....	12
2.1 Power System	12
2.2 Power Low Indication	12
2.3 Battery Replacement.....	13
2.4 Recharging the Battery Pack	13
2.5 Storage and Safety Precautions	14
Chapter 3: Operation.....	15
3.1 Ready Mode	15
3.2 User Mode and System Commands	16
3.3 Configure the Terminal in SET command.....	17
3.4 Upload/Download by ESC Command.....	18
Chapter 4 Built-in Application: FormCaching	19
4.1 Specification of FormCaching	19
4.2 How to Create a FormCaching.....	20
4.3 How to Run FormCaching.....	20
4.4 Default Setting of FormCaching	20

Chapter 1: Introduction

1.1 Overview

Thank you for choosing product from unitech Electronic Co. Ltd. PT630D, Portable Data Collection Terminal, is one of the most versatile handheld computers in the market. It is DOS compatible, capable of running programs, developed under C language. PT630D has many pre-built in functions and it is also self-programmable. In addition, it has a bundle Windows application, capable to develop many applications, specifically for your business. PT630D is light, weights only 230 grams, has a large liquid crystal display (128 pixel X 64 pixel, capable of displaying 16*8 or 8*4 characters,) rugged, and water proof. It is also capable of withstand 1.2 meter multiple drops to the concrete floor. With all these attributes, we believe PT630D is going to satisfy your needs totally. Depending on the model you had purchased, your terminal might be equipped with 3 different memory (RAM) configuration, range from 512K, 2.5MB and 4.5MB. PT630D also has offer 3 different optional communication/charging cradles. These are RS232, RS485 (daisy chain data transmission cradle) and telephone modem cradles.

1.2 Support

Over here at unitech, making you satisfy is our first priority. If at anytime, you find any problem regarding to this terminal or any our other product please feel free to contact us at; www.ute.com.tw—Asia, www.ute.com—America, www.unitech-europe.nl --Europe.

1.3 Customized PT630D

It is highly likely when you receive this terminal; it has already been customized by the system integrator or the system developer to meet your specific application. If this is the case, many operating procedures, mentioned in this manual, may not apply. Please consult your system provider for more information regarding to the customization.

1.4 Technical Specification

Physical Characteristics	
Dimensions:	165mm x 60mm x 35mm
Weight:	230g
Drop Specification:	1.2M multiple free drop to concrete floor
Display:	128 x 64 pixel; 8 lines, 16 characters per line (small font) or 4 lines, 12 characters (large font).
Battery: (include main and backup battery)	One 3.6V/880mAH Li-ion battery; One Cr2032 3V/190mAH Lithium backup battery
Environmental Sealing:	IP54
Operating Temperature:	-5C~50 C
Storage Temperature	-20C~70 C
Humidity:	5% to 95% RH, ; not condensed
Electrostatic Discharge (ESD)	4 KV for contact discharge 8 KV for air discharge
Back-Lit Display:	Yes
Keypads:	26 alphanumeric keys + one scan trigger (phosphorescent material)

Performance Characteristics	
CPU:	NEC V25 (16 bit); 80XX compatible
Operating System:	DOS compatible
Memory:	512KB/2.5MB/4.5MB
Flash ROM	256KB
Application Development:	C language, Turbo C, Visual C, JobGen plus (a window based program generator), FormCaching (a built in program generator)
Communication	RS232; Modem, Ethernet serial communication
Operating Time	Over 12 hours at 3 bar code scan per sec
Symbologies	UPC/EAN, Code 39, Interleave 2 of 5, CODABAR, MSI, Code 128, Code 93, Code 32, China Postal Code
Buzzer	Yes, over 70 dB
One LED	Dual color; Green for good; Red for bad

1.5 Quick Start

This section is designed to let you quickly get familiar with PT630D. If you need detail explanation on some of the functions, please refer to further chapters for detail explanation.

PT 630 Illustrations



Figure 0-1:PT630D front view



Figure 0-2 PT630D head view



Figure 0-3: PT630D tail view



Figure 0-4: PT630D side view



Figure 0-5: PT630D back view



Figure 0-6: PT630D charging/communication cradle, features 3 types: RS232, modem and Ethernet communication



Figure 0-7: Modem or Ethernet cradle back view



Figure 0-8: RS232 Cradle Back view



Figure 0-9: PT630D communication/charging cable (unitech part number: 600598)



Figure 0-10: PT630D Li-Ion Battery (unitech part number: 600538)

Install Main Battery

1. Remove the battery door from the PT630D by moving the screw from battery cover.
2. Insert the battery into the main battery chamber by putting the head (2 point sticking out) into the locking position first.
3. Reinstalled the battery door and tighten the screw on the battery door again.

Charging

Before using PT630D, main battery must be installed and fully charged. The PT630D is equipped with 3.6V 880m.A.H Lithium-Ion battery (Unitech part number: 600538). It should take 2 to 3 hour to fully charge the main battery.

There are 2 ways to charge the main battery:

1. Mount the unit on the cradle; connect power adaptor from the back of the cradle to any power outlet. During charging, LED above power icon will be displayed red. Once it is fully charged, LED will be turned to green.
2. Or, use the standard charging cable, which is packed with one of unitech PT630D packages or you can order them separately, together with the power adaptor. Connect the power plug of the adaptor to the charging cable, then, connect the charging cable to the main unit. Plug the power adaptor to power outlet, the unit should be in charging. The charging is completed when LED light is shown on green.


Cradle


Main battery can be charged through attaching to the PT630D charging/communication cradle (part number: PT063D-1~3) or a quick charging /communication cable (part number: 600598).

Cradle LED Icons



The icon indicates communication. When PT630D is transmitting data with the host computer, LED will flash, showing that the data is transmitting.


 The icon indicates the charging of the main unit. When the main battery is in charge on the cradle, LED will be shown red; when fully charged, the light will turn to green.

 This LED light shows the power status of the cradle itself. When the light is on, it is indicated the cradle is powered on.

Power On

After charging completely, LED is turned to green and then, you are now ready to turn on the unit. Press (☉) on the keypad to turn on the PT630D!

Communication with the Host



1. 6 Interface Ports

PT630D does its' communication via RS232 communication port located in the back of the unit. You can connect the unit via the communication cable to PC RS232 jack for data transfer or connect through cradle for communication.

1.7 Using the Keyboard

The keypad of PT630D consists of 27 rubber keys; the keyboard is configured into three different modes: **numeric mode**, **command mode**, and **alphabetic mode**. All keys except ☉ key make sound (tone) when pressed. Keys of upper four rows have larger size for easier key-pressing to input numbers.

[☉] To turn on the unit, you need to press ☉ key. To turn off the unit, you will need to press and to hold ☉ key for one second.

[CMD] Press [CMD] key and the desire command key (located at the end of the keypad) to set the keyboard to output command functions

[ESC] In **Command** or **Supervisor mode**, press [ESC] key to get back to the pervious menu.




Figure 0-11: PT630D Keypad layout

Numeric mode

PT630D keyboard is initialized to normal mode after powered on. In normal mode, the cursor is a **block** and the keyboard is mainly used to input numeric data and use F1-F4 four function-keys.

COMMAND mode

Press [CMD] key to set the keyboard to command mode. In command mode, the cursor sign is still same and the keyboard is mainly used to input special characters, make hot-key function, and use F5-F8 four function-keys.

ALPHA mode

Press [ALPHA] key to toggle between normal mode keyboard and alpha mode keyboard. In alpha mode, the cursor is an underscore sign and the keyboard is available to input upper case letters. In alpha mode, every numeric key contains 3 characters individually. You need to press the key once to get the first character, twice to get the second character and 3 times to get the third character. The characters cycles back to the first character again.

For example:

First press [ALPHA] to switch the system to alpha mode, the cursor type will be changed from block to **underscore**

To enter 'A', press the key "A" once

To get "B", press the same key twice

To get "C", press the same key 3 times.

1.8 Triggering Scanner Module

PT630D can be used with a built-in integrated laser scanner module to input data. The built-in decoder reads most barcode labels.

Users should keep laser window clean to prevent low reading rate of distorted bar code input signal.

1.9 Application Development Environment

The system of PT630D provides DOS functions and device drivers for application development, including bar code decoding, keypad input, display output, serial input/output communication, real-time-clock access and power management control.

PT630D can be programmed by the high-level Windows-based JobGen Plus program generation software or programmed by commonly used C compilers including Microsoft C, Borland C and Turbo C. An executable program generated by JobGen Plus or created by a compiler is downloaded to the unit and run on the unit.

JobGen Plus

JobGen Plus is a Windows-based program generator that gives the user an ease-of-use and comprehensive terminal application development environment. Through use-of-JobGen Plus, user can design an application program for data collection terminal by simply drawing the data collection sequence on paper, and thus, requires minimum programming skills.

For more detailed programming information, please refer to PT630D *Programming Reference Manual*, *JobGen Pro User's Manual*.

Chapter 2 Power System

2.1 Power System

Main Power

The terminal is operated by a rechargeable, 3.6V 880mAH rated Li-Ion, battery pack. The main battery should be sufficient for daily operation up to 12 hours. (Base on 5 scan per second) However, since the actual operation may vary, it is possible to result a shorter operating hours.

Backup Power

An onboard 3V 190mAH Lithium battery (CR2032) is used as the secondary power source to back up the data; the RTC (real time clock chip) and RAM memory to prevent data-loss free environment.

Normally, PT630D gets power from main power source to back-up RTC and RAM; also puts the Lithium battery in standby state. When the main power source is removed or below the level to back-up the RAM and RTC properly, the power circuit of PT630D automatically switches to the Lithium battery for back up. It is recommended that the main battery can be always placed inside the unit with enough capacity for back-up purpose in which case the Lithium battery can supply the power for up to **3 years** before consuming all its capacity up.

It is important to know that once the power in the backup battery used up, all data within the terminal will be lost. So it is very important to backup all data when replacing backup battery.

2.2 Power Low Indication

Main Battery

When the main power source reaches the battery low condition, a warning message as right icon will be shown on the LCD when PT630D is powered on or a **battery low icon sign** will emerge on the right side of the LCD.

When the main battery low occurs, the main battery can continue to supply power for about 20 ~ 40 minutes per scan /5 second; however, the unit may reach the system power cutoff point and automatically turn it off. Meanwhile the unit continues to back-up the data contents in RTC and RAM, but it cannot be powered up until the batteries have been recharged or replaced.

! WARNING! MAIN BATTERY VOLTAGE LOW

Lithium Backup Battery

When the Lithium backup battery doesn't have enough capacity to back up the system, the message as right icon will be shown on LCD when the unit is powered on. In this situation you should upload your data from the terminal immediately and replace a new Lithium battery.

! WARNING! Backup BATTERY LOW

2.3 Battery Replacement

Main Battery

- Make sure the unit is turned off.
- Turn over the unit; unscrew the battery door lock screw by turning the screw left for quarter turn.
- Slide the main battery pack from battery compartment.
- Insert the new main battery into the socket.


Remove battery pack

- Remove the main battery as previously described.
- Important! Once the backup battery is removed from the unit, all data within the unit will be lost, please backup all files before you remove the backup battery.
- Insert a new battery into the holder.
- Put the backup battery cap back on.
- Re-installed the main battery, cold start the new unit.

Make sure to back up your data in terminal before making the replacement the lithium back up battery.

2.4 Recharging the Battery Pack

When the terminal shows “Main battery low” message, the battery needs to be recharged. Plug in the power adaptor into a power outlet and connect the other end to the power outlet of PT063D, mount the terminal into the cradle, LED light on the cradle will be in red, meaning charging has begun. When the battery is fully charged, LED light will be in green. This should take 2 to 3 hours.



Charging Consideration

It is important to consider the surrounding temperature whenever you are charging the Li-Ion battery pack. The process is the most efficient in the normal room temperature or slightly cooler. It is essential for you to charge battery within the stated range of 32°F to 113°F (0°C to 45°C). Charging battery outside of the specified range could damage batteries and shorten its life cycle.

Effects of Overcharging Batteries


Overcharging may occur when a Li-Ion rechargeable battery is charged in regular or quick charging rate after it has been fully charged, but there is no risk of overcharging while charged in trickle charging rate. A battery left to charge for several weeks may appear to have minimal capacity. This type of failure can be remedied by temporarily depleting the battery of its power and recharging it to rejuvenate it. This condition can be prevented by avoiding overcharging for long period of time or always using PT063D to charge the batteries of terminal. The PT063D starts the charging process in quick charging rate and switches to trickle charging rate when it detects the battery is fully charged.

2.5 Storage and Safety Precautions

Batteries should be stored in an open environment condition and placed where there is no risk of accidental shorting or other damage. Although charged Li-Ion batteries may be left unused for several months, their capacity may be reduced due to back up and internal resistance. If this happens, they will require recharging prior to use. Li-Ion batteries may be stored at temperatures between -4°F and 158°F (-20°C to 70°C).

Chapter 3: Operation

PT630D is set up several operating modes. The system of terminal may operate in various modes for different purposes. The figure below shows the operating flow of the terminal. The following diagram summarized these operating modes to switch between different modes.



System configurations are categorized in two groups, users can select “8.SET” command in User mode to set general system configurations or enter Supervisor mode to set advanced system configurations. The **Supervisor mode** is also protected with password checking to prevent unauthorized personnel from changing the system configuration.

(For PT630D detail setup procedures please refer to PT630D Technical Binder). It is likely that your unit came pre-configure by your software vender or system developer. In this case, please be caution when changing these settings.

3.1 Ready Mode

The terminal performs a Power-On-Test and Warm-Start when it is switched on. After the Warm Start, the system enters Ready mode and shows the Ready mode prompt.

Ready mode prompt

```

PT630D Vx.xx
MEM 4608 KB
>
  
```

The first line indicates the model code and version number (e.g. V1.00). The second line shows the size of the total installed RAM (i.e. 4608 KB). The third line prompts a ">" which indicates that the terminal passed the Power-on-test and is ready to be used.

3.2 User Mode and System Commands

There are eight system commands: RUN, TER, COM, DIR, ERA, TYP, CPY, and SET. Each command can be invoked through menu-selection in **User mode**. User can press [CMD] key for two seconds in **Ready mode** to enter **User mode**.

User mode prompt

(1) RUN	(2) TER
(3) COM	(4) DIR
(5) ERA	(6) TYP
(7) CPY	(8) SET

Select the corresponding number, 1-8, or press [←] and [→] to highlight a command then hit [ENT] to select a system command. Pressing the [EXIT] key (hit [CMD], then [ALPHA]) returns to **Ready mode**.

RUN When invokes the **RUN** command, you may press the [→] key to toggle the loaded program and hit [ENT] to run the program. The program may also be executed on the terminal by entering the program name directly in Ready mode.

TER This command puts the terminal in either terminal emulation mode or FormCaching application mode depending on which function you select. Please see chapter 4 for detail on how to configure and use FormCaching. In terminal emulation mode, the terminal serves as a dumb terminal to transmit data to or receive data from a Host computer. In this mode, data input from bar code reader or keyboard is displayed on screen and output to RS-232 port. Data received from the serial port is displayed on the LCD screen. Communication parameters, such as baud rate, data bits, parity, stop bits and flow control, must be set to be compatible with the destination in order to send data properly.

COM This command puts the terminal in Kermit server mode. The following indicates the available Kermit commands at the Host/PC side:

<u>Command</u>	<u>Description</u>
Send filename	Send a file from the Host/PC to terminal and store it in the terminal's RAM disk
Get filename	Get a file from the terminal to the Host/PC disk
Remote dir	List files of the terminal RAM disk
Remote Del filename	Delete a data file stored in the terminal RAM disk

Make sure to set the terminal communication parameters to match the host/PC system before proceeding data communication. Hit [ESC] Ready mode.

DIR This command shows the files in the RAM disk with the following information:

- The list of file names stored in the RAM DISK
- The size of program execution area
- The amount of free RAM DISK space left

ERA This command deletes a file from RAM disk of terminal. After the file has been deleted, it can not be recovered.

< ERASE FILE > SCAN.EXE

TYP This command dumps the content of a file on the terminal's LCD. The content of the file will be displayed 128 (16 character x 8 line) characters at a time. Press any key to show the next page or hit [CMD] then [ALPHA]

< TYPE FILE > SCAN.DAT

keys to return to **User mode prompt**. If you try to display a program or binary file, you may only see unintelligible characters.

CPY This command allows users to make copy of data from a source device to a destination device. The source device may be a file, COM (serial input), CON (keyboard), and the destination device may be a file, COM (serial output), CON (LCD display).

Source	Dest.	Function
file1	file2	copy file1 to file2
file1	COM	output content of file1 to serial port
file1	CON	output content of file1 to LCD
COM	file2	input data from serial port and store in file2
CON	file2	input data from keyboard and store in file2, press [CMD] and then [ALPHA] key to end the data input

SET This command allows users to set system date and time, assign laser feature and enable to display power-on logo (see next section).

```
<SYSTEM SETUP>
1.DATE & TIME
2.SCANNER
3.DISPLAY
4.KEYPAD
5.EXIT
```

3.3 Configure the Terminal in SET command

There are three categories of general system configuration available in SET command. Select the corresponded number, 1-3, to set system date/time, assign scanning feature and enable power-on Logo display. Hit **[CMD]** then **[ALPHA]** keys to return to **User mode prompt**.

```
<SYSTEM SETUP>
1. DATE & TIME
2. SCANNER
3. DISPLAY
4. KEYPAD
5. EXIT
```

3.3.1 DATE & TIME:

Setting system clock & calendar

When selects "1.DATE & TIME" in **SET command menu**, the screen as right will be shown on the terminal LCD and let you set the system date and time of Real Time Clock chip (RTC). The system date and time can be retrieved in application and used as time stamp for data collection.

```
DATE-TIME
SETUP
1998/01/01
08:00:00
```

The second line shows the current date in the format YYYY/MM/DD (year/month/day). If you want to reset the system date to January 1, 1997, then enter **[1][9][9][7],[0][1],[0][1]**. Or press **[ENT]** key to skip the system date setting.

The third line shows the current time. The way to set system time is similar to set system date described above. The format of system time is expressed in 24 hour of HH:MM:SS (hour:minute:second).

3.3.2 SCANNER:

The system software of terminal decodes all major bar code symboloies including Code 39, Code 128, Codabar, Code 93, I25, EAN, UPC, China Post code, etc. Use the **[→]** key to toggle among selection in each category, then press **[ENT]** to confirm.

SCANNER Enable / disable bar code decoding

PEN SCAN KEY When pen scanner is used on PT630D, user can setup whether pressing trigger key to enable pen scanner. If **ENABLE** is selected, user must press and hold down trigger to scan barcode label. If **DISABLE** is selected, user can directly scan barcode label without pressing trigger key. Enable / Disable (Optional)

LASER AIM	Enable / disable laser beam point target on a distance barcode (for long range PT630DLR only; optional)
VERIFICATION	Enable / disable double check scanned barcode.3.3.3 DISPLAY: Enable/disable power-on logo display
ENABLE	Show system logo when power-on
DISABLE	Do not show system logo when power-on
KEYPAD:	Allow user to set UPPER / LOWER case of character
EXIT:	Leave the SET (setting) environment

3.4 Upload/Download by ESC Command

The way to upload/download by Kermit server described in section 3.2 will need the operator to set the terminal to Kermit server mode by selecting user command "3.COM" in User mode or calling system function in application program.

The hardware and software of terminal is designed that the unit can be woken up (turned on) by input from the serial port. Besides, the terminal can also be instructed to process data communication by remote ESC commands through built-in MULTI communication protocol. (Please refer to *PT630D Technical Binder* for detail information)

After linking the terminal to a PC/host through RS232 interface, a communication program running on host first sends a few of dummy bytes to the terminal and delays for about 500 mini-second to remotely wake up the unit. Then the program can send out a data pack of a remote ESC command that matches the MULTI protocol to the terminal and instruct the terminal for certain process.

For instance, the terminal will automatically execute the system routine to upload a file after receiving the valid "File upload" ESC command. Meanwhile the program running on the host should follow the control flow of MULTI protocol and process to receive the data.

For detailed description of each ESC command and protocol, please see the *PT630D Programming Reference Manual*.

Chapter 4 Built-in Application: FormCaching

The system of terminal includes a built-in application, FormCaching. It allows users to create a data entry application by specifying field prompt, type, length, input method and delimiter, etc. without writing program and loading to the terminal.

4.1 Specification of FormCaching

DATA FIELD DEFINITION: maximum field number=8			
	Category	Range	Description
1	FIELD PROMPT	max.16 characters	set field prompting
2	MIN/MAX DATA LENGTH	1-32	set minimum field length and maximum field length
3	DATA TYPE	1.NUMERIC 2.ALPHANUM	numeric data (0~9) or alphanumeric data (20H~FCH)
4	DEVICE TYPE	1.KEY ONLY 2.SCAN ONLY 3.BOTH	input by keyboard only, bar code scanning only or both
DATA RECORD DEFINITION			
	Category	Range	Description
5	BETWEEN FIELD	1.Append screen 2.Clear screen	specify to clear or append screen between two fields
6	FIELD DELIMITER	1., 2.; 3.Space 4.Tab	assign field delimiter
7	RECORD DELIMITER	1.CR 2.LF 3.CRLF	assign record delimiter
8	DATE STAMP FIELD	1:NONE 2.YYYYMMDD 3.MMDD 4.MMDDYYYY 5.DDMM 6.DDMMYYYY	specify format of Date stamp
9	TIME STAMP FIELD	1:NONE 2.HHMM 3.HHMMSS	specify format of Time stamp
10	FIELD DELAY	0-6	specify time delay between each record input in second

4.2 How to Create a FormCaching

```
FORMCACHING
1:YES
2:NO
OTHER:EXIT
```

You will need to enter Supervisor mode and select "4.FORM" category in order to set the configuration of FormCaching (refer to the *PT630D Programming Reference Manual* for how to enter the Supervisor mode). After selecting the "4.FORM" in Supervisor mode, the screen will show as above. The system will first ask user to specify four categories of the field specification including *field prompt*, *data length*, *data type* and *device type* of each data field. After completion to define all data fields, the user should hit [CMD] then [ALPHA] keys to end the setup of field specification. This step also determines the number of fields in each record and you may continue to set the rest six categories of record specification including *between field*, *field delimiter*, *record delimiter*, *date stamp field*, *time stamp field* and *field delay*.

When the FormCaching application is executed, a data file named FORM.DAT will be created to store data. The system will not allow the user to redefine FormCaching if the FORM.DAT is existed. It is necessary to delete the FORM.DAT in order to change the configuration of FormCaching.

4.3 How to Run FormCaching

When FormCaching is enabled, the built-in application can be run by selecting "2.TER" command in User mode and then select "2.FORMCACHING". The FormCaching application will follow the setting as defined to display prompting, get input and store data in the file named FORM.DAT. Hit [CMD] then [ALPHA] keys to end FormCaching and return to system Ready mode. User may use [←] key to browse a previous data record, [→] key to step to next record, press [C] key to clear the record and then input new value of every field of this record.

After collecting data, the FORM.DAT file can be uploaded to host either by invoking Kermit server in User mode described in section 3.2 or remote ESC command described in 3.4.

4.4 Default Setting of FormCaching

In default, the FormCaching is initialized with settings as shown in the table below.

DATA FIELD SPECIFICATION: field number=2		
Category		Setting
Field #1	FIELD PROMPT	ITEM:
	DATA LENGTH	32
	DATA TYPE	ALPHANUM
	DEVICE TYPE	BOTH
Field #2	FIELD PROMPT	QTY:
	DATA LENGTH	4
	DATA TYPE	NUMERIC
	DEVICE TYPE	KEY ONLY
DATA RECORD SPECIFICATION		
Category		Setting
	BETWEEN FIELD	Append screen
	FIELD DELIMITER	,
	RECORD FELIMITER	CR
	DATE STAMP FIELD	NONE
	TIME STAMP FIELD	NONE
	FIELD DELAY	0